



Yap State Public Service Corporation

PO Box 667, Power Plant Road #1

Colonia, Yap State, Federated States of Micronesia 96943

Telephone: (691)-350-4427 Fax: (691)-350-4518

CLARIFICATION # 2

Date: 7/23/2025

Bid Reference No.: YSPSC-RFQ-12-2025

Question:

As per Appendix 2: Lot 2 Technical Specification, Item 6: Fuse-Switch-Disconnectors Size 125A, please advise if each fuse and fuse holder are to be separate with its own box or one fuse box will all the fuses inside?

Same as above for Item 9: Fuse-Switch-Disconnectors Size 250A?

Clarification:

Specific packaging is not required, as long as the items are securely packed to prevent any damage during transit.

Question:

As per Appendix 2: Lot 2 Technical Specification, Item 12,13,14,15: Ground Cables, please advise if these are bare copper cables or PVC insulated ground cables.

Clarification:

Insulation type and color are unspecified; bare copper cables are preferred.

We hope this clarification encourages broader participation and ensures flexibility in sourcing while maintaining the required functionality. I apologize for the inconvenience. Please let me know if you need further information or clarification.

Thank you for your attention and continued interest.


Belinda R Gilmatam
Purchasing Officer